

REGIONAL DISTRICT OF CENTRAL OKANAGAN

BYLAW NO. 941

A Bylaw to Amend the Westside Regional Sewer System Regulation Bylaw No. 926, 2001.

WHEREAS the Regional Board of the Regional District of Central Okanagan deems it necessary to amend the Regional District of Central Okanagan Westside Regional Sewer System Regulation Bylaw under the provisions of the Local Government Act.

AND WHEREAS the Regional Board deems it advisable to amend the said bylaw;

NOW THEREFORE THE REGIONAL BOARD OF THE REGIONAL DISTRICT OF CENTRAL OKANAGAN IN OPEN MEETING ASSEMBLED ENACTS AS FOLLOWS:

1. SECTION 4 – GENERAL REQUIREMENTS
4.15 Inspection Chambers and Manholes

To amend section 4.15 by adding the following paragraph to the end of the section:

“Where there is more than one building on a parcel discharging *industrial wastewater*, each building must have a separate inspection chamber installed 1.0 meters outside the wall of the building where the building drain connects to the building sewer.”

2. This bylaw may be cited as the “Regional District of Central Okanagan Westside Regional Sewer System Regulation Amendment Bylaw No. 941, 2001”.

READ A FIRST TIME THIS 1st DAY OF October, 2001.

READ A SECOND TIME THIS 1st DAY OF October, 2001.

READ A THIRD TIME THIS 1st DAY OF October, 2001.

RECONSIDERED AND ADOPTED THIS 15th DAY OF October, 2001.



CHAIRPERSON



DIRECTOR OF CORPORATE SERVICES

I hereby certify the foregoing to be a true and correct copy of Bylaw No. 941 cited as the "Regional District of Central Okanagan Westside Regional Sewer System Regulation Amendment Bylaw No. 941, 2001", as read a third time by the Regional Board on the 1st day of October, 2001.


Dated at Kelowna, BC this
2nd day of October, 2001.



DIRECTOR OF CORPORATE SERVICES

I hereby certify the foregoing to be a true and correct copy of Bylaw No. 941 cited as the "Regional District of Central Okanagan Westside Regional Sewer System Regulation Amendment Bylaw No. 941, 2001", as adopted by the Regional Board on the 15th day of October, 2001.

Dated at Kelowna, BC this
16th day of October,
2001.



DIRECTOR OF CORPORATE SERVICES